Evidence of Performance

Calculation of thermal transmittance

Test Report No. 17-003525-PR01 (PB-A01-06-en-02)

Kompen PVC Yapi ve Insaat Mal-Client

> zemeleri Sanayi Ticaret A.S. Konya Afyon Karayolu 45. Km.

Ladik Mevkii

42435 Sarayönü - Konya

Turkey

Single leaf window - plastic Product

Profile combination: Casement-Frame

Designation ADVANCE

product details

Performance-relevant Material Polyvinylchloride (PVC-U) rigid; Dimensions (W x H) in mm 1230 x 1480; Sealing system1 x external, 1 x centre, 1 x internal; Opening direction inwards; Frame profiles; Projected width B in mm 128; Reinforcement; Material Steel; Surface treatment metallic surface (incl. galvanized); Width in mm 22; Height in mm 40; Thickness in mm 1.2; Casement; Item number 1252; Profile section, width in mm 92; Profile section, thickness in mm 91; Frame; Item number 1151; Profile section, width in mm 70; Profile section, thickness in mm 81; Glazing; Thermal transmittance U_q in W/(m²K) 0.6 (as specified by client); Configuration in mm 4/16/4/16/4; Edge cover in mm 21; Spacer; Type Metal spacer; Linear thermal transmittance \(\mathbb{Y} \) in \(\W/(mK) \) 0.08 (according to EN ISO 10077-1, Table E.1; glazing with low emissivity glass)

Special features -/-

Calculation of thermal transmittance according to EN ISO 10077-1:2009-11 09 and EN ISO 10077-2:2012-02



 $U_{\rm W}$ = 1.0 W/(m²K) $U_{\rm f} = 1.2 \, {\rm W/(m^2 K)}$

ift Rosenheim 12.12.2017

Konrad Huber, Dipl.-Ing. (FH) **Head of Testing Department Building Physics**

Till Stübben, Dipl.-Ing. (FH) Operating Testing Officer **Building Physics**



Basis *)

EN ISO 10077-1:2009-11 EN ISO 10077-2:2012-02


SG 06-mandatory NB-CPD/SG06/11/083 2011-09

ift test report 17-003525-PR01 (PB-A01-06-en-01), dated 08.12.2017

*) Correspond/s to the national standard/s (e.g. DIN EN)

Representation

Cross section of the frame profiles



Further drawings see annex

Instructions for use

The results obtained can be used by the manufacturer for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The provisions of the applicable product standard have to be observed.

Validity

The data and results given relate solely to the tested and described specimen. This test does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies. The cover sheet can be used as abstract

Contents

The report contains a total of 7 page/s and annexe (2 pages).

Notified Body 0757 PÜZ-Stelle: BAY 18

